



**BUREAU
VERITAS**

Certificate of compliance

Applicant: SolarEdge Technologies Ltd.
1 HaMada Street
Herzeliya 4673335
Israel

Product: Grid-tied photovoltaic (PV) inverter

Model: SE50K with 2 x SE25K
SE55K with 2 x SE27.6K
SE75K with 3 x SE25K
SE82.8K with 3 x SE27.6K

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G99/1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

Applied rules and standards:

Engineering Recommendation G99/1-3:2018

Requirements for the connection of generation equipment in parallel with public distribution networks

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 17TH0209-G99/1_1
Certificate number: U19-0303
Date of issue: 2019-05-20

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Type Approval and declaration of compliance with the requirements of Engineering Recommendation G99. | | | |
|--|--|--------------|--|
| PGM Technology | Photovoltaic inverter | | |
| Manufacturer: | SolarEdge Technologies Ltd. | | |
| Address | 1 HaMada Street Herzeliya 4673335 Israel | | |
| Tel | +972-9-957-6620 | Tel | +972-9-957-6620 |
| Email | info@solaredge.com | Email | info@solaredge.com |
| Rated values | SE50K | SE55K | |
| Maximum rated capacity | 50000 | 55000 | |
| Rated voltage | 230 / 400 3 wires, N, PE | | |
| Rated values | SE75K | SE82.8K | |
| Maximum rated capacity | 75000 | 82800 | |
| Rated voltage | 230 / 400 3 wires, N, PE | | |
| Firmware version | Main DSP software version is 1.130 Aux DSP software version is 2.19 | | |
| Measurement period: | 2017-06-14 to 2017-06-29, 2018-12-10 to 2018-12-19, 2019-01-10 to 2019-02-05, 2019-05-16 | | |
| Description of the structure of the power generation unit: | | | |
| The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error. | | | |
| Differences between Generating Units: | | | |
| The inverters SE27.6K is based on the inverter SE25K. They use the same control unit, control system and software. Based on the single inverter models SE25K and SE27.6K are the models build of: SE50K with 2 x SE25K SE55K with 2 x SE27.6K SE75K with 3 x SE25K SE82.8K with 3 x SE27.6K | | | |
| The above stated Generating Units are tested according the requirements in the Engineering Recommendation G99/1. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the Engineering Recommendation G99/1. | | | |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Operating Range. | |
|------------------|--|
| Test 1 | Voltage = 85% of nominal (195,5 V) Frequency = 47 Hz Power Factor = 1 Period of test 20 s |
| Connection: | Always connected |
| Limit: | Always connected |
| Test 1 | Voltage = 85% of nominal (195,5 V) Frequency = 47.5 Hz Power Factor = 1 Period of test 90 minutes |
| Connection: | Always connected |
| Limit: | Always connected |
| Test 1 | Voltage = 110% of nominal (253 V) Frequency = 51.5 Hz Power Factor = 1 Period of test 90 minutes |
| Connection: | Always connected |
| Limit: | Always connected |
| Test 1 | Voltage = 110% of nominal (253 V) Frequency = 52.0 Hz Power Factor = 1 Period of test 15 minutes |
| Connection: | Always connected |
| Limit: | Always connected |

| Protection. Voltage tests. | | | | | | |
|----------------------------|-------------|----------------|-------------|----------------|----------------|-----------------|
| Phase 1 | | | | | | |
| Function | Setting | | Trip test | | No trip test | |
| | Voltage [V] | Time delay [s] | Voltage [V] | Time delay [s] | Voltage / time | Confirm no trip |
| U/V | 184 | 2,5 | 184,1 | 2,782 | 188V / 3,5s | No trip |
| | | | | | 180V / 2,48s | No trip |
| O/V stage 1 | 262,2 | 1,0 | 261,5 | 1,255 | 258,2V 2,0s | No trip |
| O/V stage 2 | 273,7 | 0,5 | 273,1 | 0,761 | 269,7V 0,98s | No trip |
| | | | | | 277,7V 0,48s | No trip |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Protection. Voltage tests. | | | | | | |
|----------------------------|-------------|----------------|-------------|----------------|----------------|-----------------|
| Phase 2 | | | | | | |
| Function | Setting | | Trip test | | No trip test | |
| | Voltage [V] | Time delay [s] | Voltage [V] | Time delay [s] | Voltage / time | Confirm no trip |
| U/V | 184 | 2,5 | 184,1 | 2,748 | 188V / 3,5s | No trip |
| | | | | | 180V / 2,48s | No trip |
| O/V stage 1 | 262,2 | 1,0 | 261,5 | 1,261 | 258,2V 2,0s | No trip |
| O/V stage 2 | 273,7 | 0,5 | 273,1 | 0,748 | 269,7V 0,98s | No trip |
| | | | | | 277,7V 0,48s | No trip |

| Protection. Voltage tests. | | | | | | |
|----------------------------|-------------|----------------|-------------|----------------|----------------|-----------------|
| Phase 3 | | | | | | |
| Function | Setting | | Trip test | | No trip test | |
| | Voltage [V] | Time delay [s] | Voltage [V] | Time delay [s] | Voltage / time | Confirm no trip |
| U/V | 184 | 2,5 | 184,0 | 2,755 | 188V / 3,5s | No trip |
| | | | | | 180V / 2,48s | No trip |
| O/V stage 1 | 262,2 | 1,0 | 261,5 | 1,255 | 258,2V 2,0s | No trip |
| O/V stage 2 | 273,7 | 0,5 | 273,2 | 0,755 | 269,7V 0,98s | No trip |
| | | | | | 277,7V 0,48s | No trip |

Note. For Voltage tests the Voltage required to trip is the setting $\pm 3,45V$. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4V$ and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Protection. Frequency tests. | | | | | | |
|------------------------------|----------------|----------------|----------------|----------------|------------------|-----------------|
| Function | Setting | | Trip test | | No trip test | |
| | Frequency [Hz] | Time delay [s] | Frequency [Hz] | Time delay [s] | Frequency / time | Confirm no trip |
| U/F stage 1 | 47,5 | 20 | 47,50 | 20,270 | 47,7Hz / 25s | No trip |
| U/F stage 2 | 47 | 0,5 | 47,00 | 0,785 | 47,2Hz / 19,98s | No trip |
| | | | | | 46,8Hz / 0,48s | No trip |
| O/F stage 2 | 52 | 0,5 | 52,00 | 0,762 | 51,8Hz / 89,98s | No trip |
| | | | | | 52,2Hz / 0,48s | No trip |

Note. For Frequency Trip tests the Frequency required to trip is the setting $\pm 0,1$ Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The "No-trip tests" need to be carried out at the setting $\pm 0,2$ Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

| Protection. Loss of Mains. | | | | | | |
|--|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|--------------------------|
| SE50K | | | | | | |
| Inverters tested according to BS EN 62116. | | | | | | |
| Balancing load on islanded network | 33% of -5% Q Test 22 | 66% of -5% Q Test 12 | 100% of -5% P Test 5 | 33% of +5% Q Test 31 | 66% of +5% Q Test 21 | 100% of +5% P Test 10 |
| Trip time. Ph1 fuse removed [s] | 0,152 | 0,133 | 0,431 | 0,175 | 0,153 | 0,240 |
| Trip time. Ph2 fuse removed [s] | 0,152 | 0,133 | 0,431 | 0,175 | 0,153 | 0,240 |
| Trip time. Ph3 fuse removed [s] | 0,152 | 0,133 | 0,431 | 0,175 | 0,153 | 0,240 |
| SE82.8K | | | | | | |
| Inverters tested according to BS EN 62116. | | | | | | |
| Balancing load on islanded network | 33% of -5% Q Test 22 | 66% of -5% Q Test 12 | 100% of -5% P Test 5 | 33% of +5% Q Test 31 | 66% of +5% Q Test 21 | 100% of +5% P Test 10 |
| Trip time. Ph1 fuse removed [s] | 0,450 | 0,141 | 0,296 | 0,170 | 0,276 | 0,267 |
| Trip time. Ph1 fuse removed [s] | 0,450 | 0,141 | 0,296 | 0,170 | 0,276 | 0,267 |
| Trip time. Ph1 fuse removed [s] | 0,450 | 0,141 | 0,296 | 0,170 | 0,276 | 0,267 |

Note. Trip time limit is 0,5s. For technologies which have a substantial shut down time this can be added to the 0,5s in establishing that the trip occurred in less than 0,5s maximum. Shut down time could therefore be up to 1,0s for these technologies.

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Protection. Re-connection timer. | | | | |
|---|-----------------|---|-----------------|-----------------|
| Test should prove that the reconnection sequence starts in no less than 20 seconds for restoration of voltage and frequency to within the stage 1 settings of table 10.5.7.1. | | | | |
| Under Voltage (182V) | | | | |
| Time delay setting | | Measured delay | | |
| 20s | | 37,0s | | |
| Over Voltage (266,2V) | | | | |
| Time delay setting | | Measured delay | | |
| 20s | | 35,0s | | |
| Under Frequency(47,4Hz) | | | | |
| Time delay setting | | Measured delay | | |
| 20s | | 34,0 | | |
| Over Frequency(52,1Hz) | | | | |
| Time delay setting | | Measured delay | | |
| 20s | | 35,0 | | |
| | | Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1. | | |
| | At 266,2V | At 196,1V | At 47,4Hz | At 52,1Hz |
| Confirmation that the Generating Unit does not re-connect. | No reconnection | No reconnection | No reconnection | No reconnection |

| Protection. Frequency change, Stability test. | | | | |
|--|-----------------------------|---------------|----------------------|------------------------|
| | Start Frequency [Hz] | Change | Test Duration | Confirm no trip |
| Positive Vector Shift | 49,5 | +50 degrees | | No trip |
| Negative Vector Shift | 50,5 | -50 degrees | | No trip |
| Positive Frequency drift | 49,0 to 51,0 | +0,95Hz/sec | 2,1s | No trip |
| Negative Frequency drift | 51,0 to 49,0 | -0,95Hz/sec | 2,1s | No trip |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Limited Frequency Sensitive Mode – Over Frequency | | | | | | | |
|--|--------------------------|----------|----------|----------|----------|----------|----------|
| SE27.6K | | | | | | | |
| 1-min mean value [Hz]: | a) 50,00 | b) 50,45 | c) 50,70 | d) 51,15 | e) 50,70 | f) 50,45 | g) 50,00 |
| 1. Measurement a) to g): Active power output > 80% P _n | | | | | | | |
| Frequency [Hz]: | 50,00 | 50,45 | 50,70 | 51,15 | 50,70 | 50,45 | 50,00 |
| P _M [kW]: | N/A | 27,56 | 25,81 | 22,67 | 25,81 | 27,56 | N/A |
| P _{E60} [kW]: | 27,91 | 27,53 | 25,79 | 22,66 | 25,78 | 27,47 | 27,81 |
| ΔP _{E60} /P _M [%]: | N/A | -0,03 | -0,02 | -0,01 | -0,03 | -0,09 | N/A |
| 2. Measurement a) to g): Active power output 40% and 60% after freezing > 80% P _n | | | | | | | |
| Frequency [Hz]: | 50,00 | 50,45 | 50,70 | 51,15 | 50,70 | 50,45 | 50,00 |
| P _M [kW]: | N/A | 14,00 | 13,11 | 11,52 | 13,11 | 14,00 | N/A |
| P _{E60} [kW]: | 14,18 | 14,06 | 13,17 | 11,57 | 13,17 | 14,06 | 15,34 |
| ΔP _{E60} /P _M [%]: | N/A | 0,07 | 0,06 | 0,06 | 0,06 | 0,06 | N/A |
| Limit ΔP/P _{1min} : | + 10 % of P _M | | | | | | |

| Output Power with falling Frequency | | | |
|-------------------------------------|-----------------|----------------------|----------------------|
| SE27.6K | | | |
| 5-min mean value (each) | a) 50 ± 0,01 Hz | b) - 0,4 to - 0,5 Hz | c) - 2,4 to - 2,5 Hz |
| Frequency [Hz]: | 50,00 | 49,55 | 47,55 |
| Active power [W]: | 28666 | 28680 | 28703 |
| ΔP/PM [%] per 1 Hz: | | | 0 |



Annex to the G99/1 certificate of compliance No. U19-0303

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Power Quality. Harmonics.

SE50K

Phase 1

| SSEG rating per phase (rpp) | | | | | | |
|-----------------------------|-------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| | At 45-55% of rated output 9,11kW | | 100% of rated output 16,78kW | | | |
| Harmonic | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Harmonic % | |
| | | | | | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,065 | 0,090 | 0,089 | 0,123 | 8% | 8% |
| 3rd | 0,057 | 0,079 | 0,155 | 0,216 | 21,6% | N/A |
| 4th | 0,053 | 0,073 | 0,127 | 0,177 | 4% | 4% |
| 5th | 1,100 | 1,531 | 0,684 | 0,952 | 10,7% | 10,7% |
| 6th | 0,027 | 0,038 | 0,045 | 0,062 | 2,67% | 2,67% |
| 7th | 0,861 | 1,197 | 0,535 | 0,744 | 7,2% | 7,2% |
| 8th | 0,022 | 0,030 | 0,027 | 0,037 | 2% | 2% |
| 9th | 0,021 | 0,029 | 0,021 | 0,030 | 3,8% | N/A |
| 10th | 0,019 | 0,026 | 0,027 | 0,038 | 1,6% | 1,6% |
| 11th | 0,384 | 0,535 | 0,317 | 0,441 | 3,1% | 3,1% |
| 12th | 0,015 | 0,021 | 0,017 | 0,023 | 1,33% | 1,33% |
| 13th | 0,273 | 0,379 | 0,290 | 0,404 | 2% | 2% |
| 14th | 0,013 | 0,019 | 0,017 | 0,024 | N/A | N/A |
| 15th | 0,014 | 0,019 | 0,014 | 0,020 | N/A | N/A |
| 16th | 0,013 | 0,018 | 0,016 | 0,022 | N/A | N/A |
| 17th | 0,143 | 0,198 | 0,178 | 0,248 | N/A | N/A |
| 18th | 0,010 | 0,014 | 0,012 | 0,017 | N/A | N/A |
| 19th | 0,112 | 0,155 | 0,163 | 0,227 | N/A | N/A |
| 20th | 0,011 | 0,015 | 0,014 | 0,019 | N/A | N/A |
| 21th | 0,013 | 0,018 | 0,013 | 0,018 | N/A | N/A |
| 22th | 0,011 | 0,015 | 0,011 | 0,015 | N/A | N/A |
| 23th | 0,106 | 0,147 | 0,116 | 0,162 | N/A | N/A |
| 24th | 0,009 | 0,012 | 0,010 | 0,013 | N/A | N/A |
| 25th | 0,088 | 0,122 | 0,099 | 0,138 | N/A | N/A |
| 26th | 0,010 | 0,014 | 0,012 | 0,017 | N/A | N/A |
| 27th | 0,015 | 0,021 | 0,017 | 0,023 | N/A | N/A |
| 28th | 0,011 | 0,015 | 0,010 | 0,014 | N/A | N/A |
| 29th | 0,080 | 0,112 | 0,082 | 0,113 | N/A | N/A |
| 30th | 0,008 | 0,011 | 0,009 | 0,012 | N/A | N/A |
| 31th | 0,052 | 0,073 | 0,063 | 0,088 | N/A | N/A |
| 32th | 0,010 | 0,014 | 0,011 | 0,016 | N/A | N/A |
| 33th | 0,018 | 0,025 | 0,019 | 0,026 | N/A | N/A |
| 34th | 0,010 | 0,014 | 0,009 | 0,013 | N/A | N/A |
| 35th | 0,056 | 0,077 | 0,064 | 0,089 | N/A | N/A |
| 36th | 0,008 | 0,011 | 0,008 | 0,011 | N/A | N/A |
| 37th | 0,027 | 0,038 | 0,045 | 0,062 | N/A | N/A |
| 38th | 0,010 | 0,014 | 0,011 | 0,016 | N/A | N/A |
| 39th | 0,017 | 0,024 | 0,017 | 0,023 | N/A | N/A |
| 40th | 0,009 | 0,012 | 0,009 | 0,012 | N/A | N/A |
| THD | 3,84% | | 1,45% | | 23% | 13% |
| PWHD | 0,007% | | 0,003% | | 23% | 22% |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Power Quality. Harmonics.

SE50K

Phase 2

| SSEG rating per phase (rpp) | | | | | | |
|-----------------------------|-------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| | At 45-55% of rated output 9,12kW | | 100% of rated output 16,81kW | | | |
| Harmonic | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Harmonic % | |
| | | | | | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,087 | 0,121 | 0,075 | 0,104 | 8% | 8% |
| 3rd | 0,154 | 0,215 | 0,280 | 0,389 | 21,6% | N/A |
| 4th | 0,047 | 0,065 | 0,099 | 0,138 | 4% | 4% |
| 5th | 1,099 | 1,529 | 0,724 | 1,007 | 10,7% | 10,7% |
| 6th | 0,039 | 0,055 | 0,057 | 0,080 | 2,67% | 2,67% |
| 7th | 0,823 | 1,145 | 0,501 | 0,697 | 7,2% | 7,2% |
| 8th | 0,026 | 0,037 | 0,030 | 0,041 | 2% | 2% |
| 9th | 0,036 | 0,050 | 0,038 | 0,053 | 3,8% | N/A |
| 10th | 0,019 | 0,026 | 0,027 | 0,038 | 1,6% | 1,6% |
| 11th | 0,375 | 0,521 | 0,319 | 0,444 | 3,1% | 3,1% |
| 12th | 0,014 | 0,019 | 0,021 | 0,030 | 1,33% | 1,33% |
| 13th | 0,276 | 0,384 | 0,248 | 0,345 | 2% | 2% |
| 14th | 0,013 | 0,019 | 0,021 | 0,029 | N/A | N/A |
| 15th | 0,015 | 0,020 | 0,036 | 0,050 | N/A | N/A |
| 16th | 0,016 | 0,022 | 0,016 | 0,023 | N/A | N/A |
| 17th | 0,120 | 0,167 | 0,174 | 0,242 | N/A | N/A |
| 18th | 0,011 | 0,016 | 0,013 | 0,018 | N/A | N/A |
| 19th | 0,115 | 0,160 | 0,142 | 0,198 | N/A | N/A |
| 20th | 0,012 | 0,017 | 0,014 | 0,019 | N/A | N/A |
| 21th | 0,019 | 0,027 | 0,024 | 0,033 | N/A | N/A |
| 22th | 0,010 | 0,014 | 0,013 | 0,019 | N/A | N/A |
| 23th | 0,092 | 0,128 | 0,105 | 0,146 | N/A | N/A |
| 24th | 0,009 | 0,013 | 0,011 | 0,015 | N/A | N/A |
| 25th | 0,096 | 0,134 | 0,098 | 0,137 | N/A | N/A |
| 26th | 0,010 | 0,014 | 0,011 | 0,016 | N/A | N/A |
| 27th | 0,013 | 0,018 | 0,020 | 0,028 | N/A | N/A |
| 28th | 0,010 | 0,013 | 0,012 | 0,016 | N/A | N/A |
| 29th | 0,063 | 0,087 | 0,067 | 0,094 | N/A | N/A |
| 30th | 0,008 | 0,012 | 0,010 | 0,013 | N/A | N/A |
| 31th | 0,073 | 0,102 | 0,076 | 0,106 | N/A | N/A |
| 32th | 0,011 | 0,015 | 0,010 | 0,014 | N/A | N/A |
| 33th | 0,011 | 0,016 | 0,014 | 0,019 | N/A | N/A |
| 34th | 0,011 | 0,016 | 0,011 | 0,016 | N/A | N/A |
| 35th | 0,033 | 0,046 | 0,046 | 0,063 | N/A | N/A |
| 36th | 0,008 | 0,011 | 0,009 | 0,012 | N/A | N/A |
| 37th | 0,049 | 0,068 | 0,061 | 0,085 | N/A | N/A |
| 38th | 0,009 | 0,013 | 0,009 | 0,013 | N/A | N/A |
| 39th | 0,012 | 0,017 | 0,012 | 0,016 | N/A | N/A |
| 40th | 0,011 | 0,015 | 0,011 | 0,015 | N/A | N/A |
| THD | 3,80% | | 1,48% | | 23% | 13% |
| PWHD | 0,007% | | 0,003% | | 23% | 22% |



BUREAU
VERITAS

Annex to the G99/1 certificate of compliance No. U19-0303

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Power Quality. Harmonics.

SE50K

Phase 3

| SSEG rating per phase (rpp) | | | | | | |
|-----------------------------|-------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| Harmonic | At 45-55% of rated output 8,97kW | | 100% of rated output 16,58kW | | Harmonic % | |
| | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,092 | 0,130 | 0,085 | 0,119 | 8% | 8% |
| 3rd | 0,162 | 0,227 | 0,235 | 0,330 | 21,6% | N/A |
| 4th | 0,049 | 0,069 | 0,069 | 0,096 | 4% | 4% |
| 5th | 1,127 | 1,583 | 0,726 | 1,019 | 10,7% | 10,7% |
| 6th | 0,034 | 0,048 | 0,031 | 0,044 | 2,67% | 2,67% |
| 7th | 0,918 | 1,289 | 0,586 | 0,824 | 7,2% | 7,2% |
| 8th | 0,026 | 0,037 | 0,030 | 0,042 | 2% | 2% |
| 9th | 0,167 | 0,235 | 0,168 | 0,236 | 3,8% | N/A |
| 10th | 0,020 | 0,028 | 0,024 | 0,033 | 1,6% | 1,6% |
| 11th | 0,448 | 0,630 | 0,341 | 0,479 | 3,1% | 3,1% |
| 12th | 0,016 | 0,022 | 0,019 | 0,027 | 1,33% | 1,33% |
| 13th | 0,310 | 0,435 | 0,352 | 0,495 | 2% | 2% |
| 14th | 0,015 | 0,020 | 0,021 | 0,029 | N/A | N/A |
| 15th | 0,095 | 0,133 | 0,119 | 0,167 | N/A | N/A |
| 16th | 0,014 | 0,019 | 0,018 | 0,025 | N/A | N/A |
| 17th | 0,195 | 0,274 | 0,252 | 0,353 | N/A | N/A |
| 18th | 0,012 | 0,017 | 0,014 | 0,019 | N/A | N/A |
| 19th | 0,113 | 0,159 | 0,145 | 0,204 | N/A | N/A |
| 20th | 0,013 | 0,018 | 0,014 | 0,020 | N/A | N/A |
| 21th | 0,055 | 0,077 | 0,046 | 0,064 | N/A | N/A |
| 22th | 0,011 | 0,015 | 0,015 | 0,021 | N/A | N/A |
| 23th | 0,109 | 0,154 | 0,127 | 0,179 | N/A | N/A |
| 24th | 0,010 | 0,015 | 0,011 | 0,016 | N/A | N/A |
| 25th | 0,102 | 0,144 | 0,110 | 0,154 | N/A | N/A |
| 26th | 0,011 | 0,015 | 0,013 | 0,018 | N/A | N/A |
| 27th | 0,037 | 0,052 | 0,041 | 0,057 | N/A | N/A |
| 28th | 0,012 | 0,017 | 0,013 | 0,018 | N/A | N/A |
| 29th | 0,069 | 0,097 | 0,084 | 0,119 | N/A | N/A |
| 30th | 0,009 | 0,012 | 0,010 | 0,014 | N/A | N/A |
| 31th | 0,088 | 0,123 | 0,099 | 0,138 | N/A | N/A |
| 32th | 0,013 | 0,018 | 0,011 | 0,015 | N/A | N/A |
| 33th | 0,019 | 0,026 | 0,010 | 0,014 | N/A | N/A |
| 34th | 0,012 | 0,017 | 0,011 | 0,016 | N/A | N/A |
| 35th | 0,069 | 0,097 | 0,090 | 0,126 | N/A | N/A |
| 36th | 0,009 | 0,013 | 0,009 | 0,013 | N/A | N/A |
| 37th | 0,032 | 0,045 | 0,054 | 0,075 | N/A | N/A |
| 38th | 0,011 | 0,015 | 0,011 | 0,015 | N/A | N/A |
| 39th | 0,029 | 0,041 | 0,031 | 0,043 | N/A | N/A |
| 40th | 0,012 | 0,016 | 0,011 | 0,015 | N/A | N/A |
| THD | 4,17% | | 1,64% | | 23% | 13% |
| PWHD | 0,008% | | 0,004% | | 23% | 22% |



Annex to the G99/1 certificate of compliance No. U19-0303

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 17TH0209-G99/1_1

| Power Quality. Harmonics. | | | | | | |
|-----------------------------|--------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| SE82.8K | | | | | | |
| Phase 1 | | | | | | |
| SSEG rating per phase (rpp) | | | | | | |
| | At 45-55% of rated output 15,01kW | | 100% of rated output 27,63kW | | | |
| Harmonic | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Harmonic % | |
| | | | | | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,075 | 0,064 | 0,113 | 0,096 | 8% | 8% |
| 3rd | 0,117 | 0,099 | 0,344 | 0,291 | 21,6% | N/A |
| 4th | 0,091 | 0,077 | 0,173 | 0,146 | 4% | 4% |
| 5th | 0,735 | 0,621 | 0,481 | 0,407 | 10,7% | 10,7% |
| 6th | 0,039 | 0,033 | 0,094 | 0,079 | 2,67% | 2,67% |
| 7th | 0,593 | 0,501 | 0,325 | 0,275 | 7,2% | 7,2% |
| 8th | 0,027 | 0,023 | 0,042 | 0,035 | 2% | 2% |
| 9th | 0,022 | 0,018 | 0,029 | 0,025 | 3,8% | N/A |
| 10th | 0,025 | 0,021 | 0,031 | 0,026 | 1,6% | 1,6% |
| 11th | 0,351 | 0,296 | 0,239 | 0,202 | 3,1% | 3,1% |
| 12th | 0,015 | 0,013 | 0,022 | 0,018 | 1,33% | 1,33% |
| 13th | 0,296 | 0,250 | 0,221 | 0,187 | 2% | 2% |
| 14th | 0,015 | 0,013 | 0,020 | 0,017 | N/A | N/A |
| 15th | 0,023 | 0,020 | 0,017 | 0,014 | N/A | N/A |
| 16th | 0,013 | 0,011 | 0,018 | 0,015 | N/A | N/A |
| 17th | 0,191 | 0,161 | 0,146 | 0,123 | N/A | N/A |
| 18th | 0,011 | 0,009 | 0,015 | 0,012 | N/A | N/A |
| 19th | 0,146 | 0,123 | 0,137 | 0,116 | N/A | N/A |
| 20th | 0,012 | 0,010 | 0,014 | 0,012 | N/A | N/A |
| 21th | 0,026 | 0,022 | 0,012 | 0,010 | N/A | N/A |
| 22th | 0,010 | 0,008 | 0,012 | 0,010 | N/A | N/A |
| 23th | 0,117 | 0,099 | 0,098 | 0,083 | N/A | N/A |
| 24th | 0,008 | 0,007 | 0,010 | 0,008 | N/A | N/A |
| 25th | 0,081 | 0,068 | 0,089 | 0,075 | N/A | N/A |
| 26th | 0,010 | 0,009 | 0,013 | 0,011 | N/A | N/A |
| 27th | 0,020 | 0,017 | 0,011 | 0,010 | N/A | N/A |
| 28th | 0,009 | 0,007 | 0,010 | 0,009 | N/A | N/A |
| 29th | 0,072 | 0,061 | 0,070 | 0,059 | N/A | N/A |
| 30th | 0,007 | 0,006 | 0,008 | 0,007 | N/A | N/A |
| 31th | 0,051 | 0,043 | 0,057 | 0,049 | N/A | N/A |
| 32th | 0,010 | 0,009 | 0,012 | 0,010 | N/A | N/A |
| 33th | 0,015 | 0,012 | 0,011 | 0,010 | N/A | N/A |
| 34th | 0,008 | 0,007 | 0,010 | 0,009 | N/A | N/A |
| 35th | 0,049 | 0,042 | 0,057 | 0,048 | N/A | N/A |
| 36th | 0,007 | 0,006 | 0,008 | 0,007 | N/A | N/A |
| 37th | 0,035 | 0,030 | 0,040 | 0,034 | N/A | N/A |
| 38th | 0,010 | 0,009 | 0,010 | 0,009 | N/A | N/A |
| 39th | 0,010 | 0,009 | 0,011 | 0,009 | N/A | N/A |
| 40th | 0,009 | 0,007 | 0,009 | 0,008 | N/A | N/A |
| THD | 1,72% | | 0,70% | | 23% | 13% |
| PWHD | 0,005% | | 0,001% | | 23% | 22% |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99 Nr. 17TH0209-G99/1_1

| Power Quality. Harmonics. | | | | | | |
|-----------------------------|--------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| SE82.8K | | | | | | |
| Phase 2 | | | | | | |
| SSEG rating per phase (rpp) | | | | | | |
| | At 45-55% of rated output 15,03kW | | 100% of rated output 27,69kW | | | |
| Harmonic | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Harmonic % | |
| | | | | | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,071 | 0,060 | 0,097 | 0,082 | 8% | 8% |
| 3rd | 0,235 | 0,199 | 0,460 | 0,388 | 21,6% | N/A |
| 4th | 0,074 | 0,062 | 0,161 | 0,136 | 4% | 4% |
| 5th | 0,774 | 0,654 | 0,635 | 0,536 | 10,7% | 10,7% |
| 6th | 0,052 | 0,044 | 0,078 | 0,066 | 2,67% | 2,67% |
| 7th | 0,552 | 0,467 | 0,348 | 0,294 | 7,2% | 7,2% |
| 8th | 0,029 | 0,024 | 0,027 | 0,023 | 2% | 2% |
| 9th | 0,043 | 0,037 | 0,034 | 0,029 | 3,8% | N/A |
| 10th | 0,025 | 0,021 | 0,030 | 0,026 | 1,6% | 1,6% |
| 11th | 0,337 | 0,285 | 0,239 | 0,202 | 3,1% | 3,1% |
| 12th | 0,018 | 0,015 | 0,025 | 0,021 | 1,33% | 1,33% |
| 13th | 0,281 | 0,237 | 0,187 | 0,158 | 2% | 2% |
| 14th | 0,019 | 0,016 | 0,018 | 0,015 | N/A | N/A |
| 15th | 0,027 | 0,023 | 0,040 | 0,034 | N/A | N/A |
| 16th | 0,015 | 0,013 | 0,020 | 0,016 | N/A | N/A |
| 17th | 0,163 | 0,138 | 0,142 | 0,120 | N/A | N/A |
| 18th | 0,011 | 0,009 | 0,015 | 0,012 | N/A | N/A |
| 19th | 0,157 | 0,133 | 0,106 | 0,089 | N/A | N/A |
| 20th | 0,012 | 0,010 | 0,012 | 0,010 | N/A | N/A |
| 21th | 0,011 | 0,010 | 0,031 | 0,027 | N/A | N/A |
| 22th | 0,012 | 0,010 | 0,017 | 0,015 | N/A | N/A |
| 23th | 0,091 | 0,077 | 0,092 | 0,078 | N/A | N/A |
| 24th | 0,009 | 0,008 | 0,009 | 0,008 | N/A | N/A |
| 25th | 0,101 | 0,086 | 0,075 | 0,063 | N/A | N/A |
| 26th | 0,010 | 0,009 | 0,012 | 0,010 | N/A | N/A |
| 27th | 0,008 | 0,007 | 0,025 | 0,021 | N/A | N/A |
| 28th | 0,010 | 0,008 | 0,014 | 0,011 | N/A | N/A |
| 29th | 0,057 | 0,048 | 0,058 | 0,049 | N/A | N/A |
| 30th | 0,008 | 0,007 | 0,009 | 0,007 | N/A | N/A |
| 31th | 0,068 | 0,057 | 0,060 | 0,050 | N/A | N/A |
| 32th | 0,009 | 0,008 | 0,012 | 0,011 | N/A | N/A |
| 33th | 0,008 | 0,007 | 0,018 | 0,015 | N/A | N/A |
| 34th | 0,010 | 0,009 | 0,011 | 0,009 | N/A | N/A |
| 35th | 0,037 | 0,031 | 0,036 | 0,031 | N/A | N/A |
| 36th | 0,007 | 0,006 | 0,008 | 0,006 | N/A | N/A |
| 37th | 0,045 | 0,038 | 0,048 | 0,040 | N/A | N/A |
| 38th | 0,009 | 0,008 | 0,011 | 0,009 | N/A | N/A |
| 39th | 0,008 | 0,007 | 0,016 | 0,014 | N/A | N/A |
| 40th | 0,010 | 0,009 | 0,010 | 0,009 | N/A | N/A |
| THD | 1,74% | | 0,82% | | 23% | 13% |
| PWHD | 0,004% | | 0,001% | | 23% | 22% |



BUREAU
VERITAS

Annex to the G99/1 certificate of compliance No. U19-0303

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Power Quality. Harmonics.

SE82.8K

Phase 3

| SSEG rating per phase (rpp) | | | | | | |
|-----------------------------|--------------------------------------|----------------------------|---------------------------------|----------------------------|-------------------------------|---------|
| Harmonic | At 45-55% of rated output 14,83kW | | 100% of rated output 27,38kW | | Harmonic % | |
| | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Measured Value (MV) in [A] | Measured Value (MV) in [%] | Limit in BS EN61000-3-12 in % | |
| | | | | | 1 phase | 3 phase |
| 2nd | 0,098 | 0,084 | 0,127 | 0,108 | 8% | 8% |
| 3rd | 0,258 | 0,220 | 0,414 | 0,353 | 21,6% | N/A |
| 4th | 0,046 | 0,039 | 0,087 | 0,074 | 4% | 4% |
| 5th | 0,818 | 0,697 | 0,544 | 0,464 | 10,7% | 10,7% |
| 6th | 0,028 | 0,024 | 0,040 | 0,034 | 2,67% | 2,67% |
| 7th | 0,664 | 0,566 | 0,413 | 0,352 | 7,2% | 7,2% |
| 8th | 0,029 | 0,024 | 0,034 | 0,029 | 2% | 2% |
| 9th | 0,206 | 0,176 | 0,174 | 0,148 | 3,8% | N/A |
| 10th | 0,021 | 0,018 | 0,026 | 0,022 | 1,6% | 1,6% |
| 11th | 0,370 | 0,316 | 0,264 | 0,225 | 3,1% | 3,1% |
| 12th | 0,016 | 0,014 | 0,019 | 0,016 | 1,33% | 1,33% |
| 13th | 0,384 | 0,327 | 0,292 | 0,249 | 2% | 2% |
| 14th | 0,019 | 0,016 | 0,017 | 0,014 | N/A | N/A |
| 15th | 0,099 | 0,084 | 0,098 | 0,084 | N/A | N/A |
| 16th | 0,016 | 0,014 | 0,019 | 0,016 | N/A | N/A |
| 17th | 0,260 | 0,222 | 0,209 | 0,178 | N/A | N/A |
| 18th | 0,011 | 0,009 | 0,013 | 0,011 | N/A | N/A |
| 19th | 0,121 | 0,103 | 0,132 | 0,112 | N/A | N/A |
| 20th | 0,012 | 0,010 | 0,013 | 0,011 | N/A | N/A |
| 21th | 0,053 | 0,045 | 0,041 | 0,035 | N/A | N/A |
| 22th | 0,012 | 0,010 | 0,017 | 0,014 | N/A | N/A |
| 23th | 0,111 | 0,094 | 0,121 | 0,103 | N/A | N/A |
| 24th | 0,008 | 0,007 | 0,011 | 0,009 | N/A | N/A |
| 25th | 0,083 | 0,071 | 0,098 | 0,084 | N/A | N/A |
| 26th | 0,011 | 0,009 | 0,013 | 0,011 | N/A | N/A |
| 27th | 0,038 | 0,032 | 0,048 | 0,041 | N/A | N/A |
| 28th | 0,010 | 0,009 | 0,015 | 0,013 | N/A | N/A |
| 29th | 0,050 | 0,043 | 0,071 | 0,061 | N/A | N/A |
| 30th | 0,007 | 0,006 | 0,009 | 0,008 | N/A | N/A |
| 31th | 0,071 | 0,061 | 0,089 | 0,076 | N/A | N/A |
| 32th | 0,009 | 0,008 | 0,012 | 0,010 | N/A | N/A |
| 33th | 0,027 | 0,023 | 0,011 | 0,010 | N/A | N/A |
| 34th | 0,010 | 0,008 | 0,013 | 0,011 | N/A | N/A |
| 35th | 0,053 | 0,045 | 0,068 | 0,058 | N/A | N/A |
| 36th | 0,007 | 0,006 | 0,008 | 0,007 | N/A | N/A |
| 37th | 0,021 | 0,018 | 0,053 | 0,045 | N/A | N/A |
| 38th | 0,009 | 0,008 | 0,011 | 0,009 | N/A | N/A |
| 39th | 0,014 | 0,012 | 0,020 | 0,017 | N/A | N/A |
| 40th | 0,010 | 0,008 | 0,011 | 0,009 | N/A | N/A |
| THD | 2,01% | | 0,84% | | 23% | 13% |
| PWHD | 0,007% | | 0,002% | | 23% | 22% |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

| Power Quality. Power factor. | | | | |
|------------------------------|--------|-------|-------|---|
| SE50K | | | | |
| Output power | 216,2V | 230V | 253V | Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1,5\%$ of the stated level during the test. |
| 20% | 0,995 | 0,993 | 0,989 | |
| 50% | 0,999 | 0,999 | 0,998 | |
| 75% | 0,999 | 0,999 | 0,999 | |
| 100% | 0,999 | 0,999 | 0,999 | |
| Limit | >0,95 | >0,95 | >0,95 | |
| SE82.8K | | | | |
| Output power | 216,2V | 230V | 253V | Measured at three voltage levels and at full output. Voltage to be maintained within $\pm 1,5\%$ of the stated level during the test. |
| 20% | 0,998 | 0,997 | 0,996 | |
| 50% | 0,999 | 0,999 | 0,999 | |
| 75% | 0,999 | 0,999 | 0,999 | |
| 100% | 0,999 | 0,999 | 0,999 | |
| Limit | >0,95 | >0,95 | >0,95 | |

| Power Quality. Voltage fluctuation and Flicker. | | | | | | | | |
|---|----------|---------------|---------------|----------|----------------|---------------|---------|-------------|
| SE25K | | | | | | | | |
| | Starting | | | Stopping | | | Running | |
| | dmax | dc | d(t) | dmax | dc | d(t) | Pst | Plt 2 hours |
| Measured values at test impedance | 0,33% | 3,3% | 0,0% | 0,33% | 3,3% | 0,0% | 0,38 | 0,38 |
| Normalised to standard impedance | 0,30% | 3,03% | 0% | 0,30% | 3,03% | 0% | 0,0787 | 0,0787 |
| Limits set under BS EN 61000-3-11 | 4% | 3,3% | 3,3% 500ms | 4% | 3,3% | 3,3% 500ms | 1,0 | 0,65 |
| Test impedance | R | 0,24* 0,4^ | Ω | XI | 0,15* 0,25 | Ω | | |
| Standard impedance | R | 0,24* 0,4^ | Ω | XI | 0,15* 0,25^ | Ω | | |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Power Quality. DC injection.

SE50K

Phase 1

| | | | |
|----------------------|-------|------|------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 11,62 | 8,06 | 5,63 |
| Recorded value [%] | 0,02 | 0,1 | 0,01 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

Phase 2

| | | | |
|----------------------|-------|-------|-------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 46,85 | 49,43 | 40,86 |
| Recorded value [%] | 0,07 | 0,07 | 0,06 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

Phase 3

| | | | |
|----------------------|-------|-------|-------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 79,51 | 78,74 | 76,22 |
| Recorded value [%] | 0,11 | 0,11 | 0,11 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

SE82.8K

Phase 1

| | | | |
|----------------------|------|------|------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 4,93 | 4,37 | 5,98 |
| Recorded value [%] | 0,00 | 0,00 | 0,00 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

Phase 2

| | | | |
|----------------------|-------|-------|-------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 48,58 | 49,33 | 35,13 |
| Recorded value [%] | 0,04 | 0,04 | 0,03 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

Phase 3

| | | | |
|----------------------|-------|-------|-------|
| Test level power [%] | 10 | 55 | 100 |
| Recorded value [mA] | 64,58 | 70,34 | 56,93 |
| Recorded value [%] | 0,05 | 0,06 | 0,05 |
| Limit [%] | 0,25 | 0,25 | 0,25 |

Appendix A2-3 Compliance Verification Report for Inverter Connected Power Generating Modules

Extract from test report according to the Engineering Recommendation G99

Nr. 17TH0209-G99/1_1

Fault level Contribution.

SE27.6K

| For a directly coupled SSEG | | | For a Inverter SSEG | | |
|--|----------|-------|---------------------|-----------|----------|
| Parameter | Symbol | Value | Time after fault | Volts [V] | Amps [A] |
| Peak Short Circuit current | I_p | N/A | 20ms | 45,3 | 37,3 |
| Initial Value of aperiodic current | A | N/A | 100ms | 45,3 | 37,3 |
| Initial symmetrical short-circuit current* | I_k | N/A | 250ms | 44,2 | 37,0 |
| Decaying (aperiodic) component of short circuit current* | i_{DC} | N/A | 500ms | 44,2 | 37,0 |
| Reactance/Resistance Ratio of source* | X/R | N/A | Time to Trip [s] | 0,507 | |

For rotating machines and linear piston machines the test should produce a 0s – 2s plot of the short circuit current as seen at the Generating Unit terminals.

* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot.

| | |
|---|--|
| Self Monitoring – Solid state switching. | N/A |
| It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0,5 seconds. | N/A (No solid state switching device) |

| | |
|---|----------|
| Logic Interface (input port) Required by paragraph 11.1.3 | P |
| Confirm that an input port is provided and can be used to shut down the module. | Yes |