

Certificate

Applicant: **SolarEdge Technologies**
6 HeHarash St.
Hod Hasharon, 45240
Israel

Product: **Photovoltaic Inverter with integrated automatic disconnection device between a generator and the public low-voltage grid**

Model:	SE2200	SE3000	SE3300	SE3500	SE4000 -16A	SE4000	SE5000	SE6000
Rating:	2200W	3000W	3300W	3500W	3680W	4000W	5000W	6000W

Intended use:

An automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G59/3 for photovoltaic systems with a single-phase parallel coupling via an inverter to the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

Engineering Recommendation G59/3
Issue 3 – September 2013

Recommendations for the connection of generating plant to the distribution systems of licensed distribution network operators


The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 11KFS055-22

Certificate No: 14-014-00

Date of issue: 2014-02-10

Valid until: 2017-02-10



Horst Haug
Certification Department

